

Characteristics of installed MPPE units Produced / Process / Wastewater (1)

Unit	Flow rate m ³ /hr (1)	Composition	Influent concentration mg/l (ppm)	Effluent concentration mg/l (ppm)
The Netherlands				
Vermilion (Total) (Harlingen) (3)	4-6	Al, Ar esp. benzene	2000-3000	< 0.5
Allied Signal, Weert	0.2	CFHC, CHC	5	< 0.010
Akzo Nobel Industrial Fibers, Arnhem	25	Solvesso	400	< 0.050
LBC Rotterdam bv; Groupe Fimalac	15/0.1	CHC, Ar	5/2000	≤ 0.1
Shell/Exxon (NAM B.V.), Offshore Gas Produced water, k15A	3-5	Al, Ar, PAH	800-1000	> 90% removal
Shell/Exxon (NAM B.V.), Offshore Gas Produced water k15B	3-5	Al, Ar, PAH	800-1000	> 90% removal
Total E&P, Offshore Gas Produced water	3	Al, Ar, PAH	600-700	> 90% removal
Germany				
Philips Bildröhrenfabrik, Aachen	5	Ar	500	< 0.05
France				
Gaz de France	3	THT	75	< 0.5
Synthexim Calais (3) (4)	6	Ar, CHC, COD	1400 – 11000	> 99.9% removal
Norway				
StatoilHydro/Shell, Ormen Lange Offshore Gas Produced water	68	Al, Ar, PAH	45	>99% removal
StatoilHydro Kollsnes Offshore Gas PW	10	Al, Ar, PAH	240	>99% removal
Offshore Atlantic StatoilHydro Åsgard Å (2)	3	Ar, PAH	70-80	> 98% removal
Offshore Atlantic StatoilHydro Troll B (oil) (2)	9	Al, Ar, PAH	15-25	95-99% removal
United States of America				
Akzo Nobel Resins, Louisville	3	Ar	150	< 0.05
Akzo Nobel Resins, East St. Louis	3	Ar	150	< 0.05
Northeast Chemical Manufacturer	16	CHC	225	< 0.2
Total Fina Elf, Houston	3	Ar	150	< 0.05
Total Fina Elf, Milwaukee	3	Ar	150	< 0.05
Midwestern Chemical Manufacturer	10	Ar, CHC	300	< 0.03
Albemarle Tyrone	6	Ar, CHC	800	< 1
Rest of World				
Offshore South China Sea (2)	3	Al, Ar	200-500	> 99% removal
Woodside Pluto Australia, LNG Terminal	40	Al, Ar, PAH	Hundreds	> 99% removal

(1) m³/hr = 4.4 gpm
(2) Long duration test

(3) Combined groundwater and process water
(4) Combined with biotreatment
(5) Surfactant Enhanced Aquifer Remediation of DNAPL (SEAR)
(6) GROs = Gasoline Range Organics (C7 – C10)
(7) DROs = Diesel Range Organics (C11 – C27)

Abbreviations:

CHC= Chlorinated Hydrocarbons
Al = Aliphatics
CFHC= Chlorinated Fluorated HC's
THT = Tetrahydrothiophene

Ar = Aromatics (BTEX)
PAH = Poly Aromatic Hydrocarbons
DNAPL = Dense Non Aqueous Phase Liquids

For more information about the MPPE Technology please contact:
VWS MPP Systems B.V. For North and South America
 Tel +31 318 66 4010 Whittier Filtration Inc.
 The Netherlands Tel. +1 562 204 2555
 USA
 Email: MPPSystems@Veoliawater.com Email: whittier.filtration@veoliawater.com

www.VWSMPPSystems.com

dd. 22.06.2009

Characteristics of installed MPPE units Groundwater (2)

Unit	Flow rate m ³ /hr (1)	Composition	Influent concentration mg/l (ppm)	Effluent concentration mg/l (ppm)
The Netherlands				
Vermilion (Total) (Harlingen) (3)	4-6	Al, Ar esp. benzene	2000-3000	< 0.5
LBC Rotterdam bv; DBOFM (3)	15/0.1	CHC	5/2000	≤ 0.1
Schering Plough, Oss	40	Al, Ar, CHC	600	<1
Solvay Pharmaceuticals, Amsterdam	25	CHC	100	< 0.01
Germany				
Zürich Insurances, Site Akzo Nobel Chemicals, Mannheim	18	CHC, (vinyl chloride)	5	< 0.006
Stadtwerke Flensburg GmbH, Flensburg	6	Ar (BTEX) PAH	14	< 0.01
Chemical Manufacturer Ruhr area DBOM(3)	120	CHC, Ar	0.6	< 0.01
Chemical Manufacturer Cologne area	50	CHC	13.8	< 0.1
AlSCO, Castrop Rauxel (5)	5-15	DNAPL, CHC	Hundreds	> 99% removal
LMBV HB 21n, Schwarze Pumpe	6	Ar, PAHs	50 –150	> 95% removal
LMBV HB 23n, Schwarze Pumpe	10	Ar, PAHs	50 –150	> 95% removal
LMBV HB 27n, Schwarze Pumpe	20	Ar, PAHs	50 –150	> 95% removal
LMBV HB 72n, Schwarze Pumpe	20	Ar, PAHs	50 –150	> 95% removal
LMBV HB 96n, Schwarze Pumpe	20	Ar, PAHs	50 –150	> 95% removal
LMBV Lauchhammer Kokerei (2)	3	Ar, PAHs	140	> 99,9% removal
LMBV Lauchhammer Tanklager (2)	5	Ar, PAHs	50	> 99,9% removal
Oil & Gas Company Dortmund (2)	5	MTBE, BTEX	15	> 99% removal
Italy				
Agip Livorno (2)	5	BTEX, MTBE, GROs(6), DROs (7)	8-10	> 99% removal
France				
Synthexim Calais (3) (4)	6	Ar, CHC, COD (4)	1400 – 11000	> 99.9% removal
Water Service Company (2)	2	CHC, BTEX	700	< 0.5
United States of America				
Akzo Nobel Chemicals LeMoyne (pilot) Alabama (2)	5 – 10	CS ₂ , CHC	30	< 0.2
Akzo Nobel Coating, Lenoir, North Carolina	1	Ar	100	< 0.005
Rest of World				
Libya Brega (3)	20	Gasoline, Diesel	1000	> 99% removal

(1) m³/hr = 4.4 gpm

(2) Long duration Field test

(3) Groundwater combined with waste water and/or process water

(4) Combined with biotreatment

(5) Surfactant Enhanced Aquifer Remediation of DNAPL (SEAR)

(6) GROs = Gasoline Range Organics (C7 – C10)

(7) DROs = Diesel Range Organics (C11 – C27)

Abbreviations:

CHC= Chlorinated Hydrocarbons

Al = Aliphatics

CFHC = Chlorinated Fluorinated HC's

THT = Tetrahydrothiophene

Ar = Aromatics (BTEX)

PAH = Poly Aromatic Hydrocarbons

DNAPL = Dense Non Aqueous Phase Liquids

DBOFM = Design Build Own Finance Maintain

DBOM = Design Build Operate Maintain

dd. 22.06. 2009

For more information about the MPPE Technology please contact:

VWS MPP Systems B.V.

Tel +31 318 66 4010

The Netherlands

Email: MPPSystems@Veoliawater.com

For North and South America

Whittier Filtration Inc.

Tel. +1 562 204 2555

USA

Email: whittier.filtration@veoliawater.com

www.VWSMPPSystems.com